



**REVISIONS:**

No.	DATE	REVISION
1	01/18/08	REVISED FOR CONSTRUCTION

- GENERAL NOTES:**
- AS-BUILT EXISTING CONDITIONS PROVIDED BY COASTAL ENGINEERING CO., INC., 260 CRANBERRY HWY., ORLEANS, MA 02653. LOCATION AND DEPTH OF UNDERGROUND UTILITIES IS APPROXIMATE ONLY, AND IS NOT WARRANTED TO BE CORRECT. ADDITIONAL UTILITIES MAY EXIST WHICH ARE NOT INDICATED ON THESE PLANS. ALL EXISTING UTILITIES SHALL BE VERIFIED FOR SERVICE, SIZE, INVERT ELEVATION, LOCATIONS, ETC. PRIOR TO NEW CONNECTIONS TO OR RELOCATION OF SAME. CONTRACTOR MUST NOTIFY DIG-SAFE AT 1-888-344-7233 AT LEAST 72 HOURS PRIOR TO ANY CONSTRUCTION. NOTIFY THIS FIRM IN WRITING OF ANY AND ALL DISCREPANCIES PRIOR TO COMMENCING ANY WORK.
  - REFER TO BID DOCUMENTS FOR ADDITIONAL INSTRUCTION.
  - ALL EXISTING AIR AND VENT PIPING TO BE ABANDONED IN PLACE OR REMOVED.
  - ELECTRICAL CONDUITS NOT INDICATED AND WILL BE REQUIRED. PROPOSED JUNCTION BOXES TO BE LOCATED AGAINST THE CONTROL BUILDING ADJACENT TO THE EXISTING BOXES.
  - EXISTING WASTEWATER TREATMENT PLAN PIPING SHOWN ON THIS PLAN WAS COMPILED FROM AS-BUILT INFORMATION PROVIDED BY COASTAL ENGINEERING COMPANY INC AND DESIGN PLANS ENTITLED "CHATHAM BARS INN; SHORE ROAD CHATHAM, MASSACHUSETTS; PROPOSED SEWAGE TREATMENT AND DISPOSAL SYSTEM" DATED JULY 11, 1997 AND REVISED THROUGH DECEMBER 5, 2000 PREPARED BY COASTAL ENGINEERING COMPANY, INC.
  - ALL VENTS SHALL PITCH CONTINUOUSLY UP FROM TANKS TO ODOR CONTROL UNIT.
  - STORM SEWERS AND LEACHING SYSTEMS TO BE DESIGNED AFTER CONTOURS ARE DEVELOPED. NEW DRAINAGE STRUCTURES WILL BE REQUIRED.

**COLER & COLANTONIO INC**  
 ENGINEERS AND SCIENTISTS

781-982-5400 101 Accord Park Drive  
 Fax: 781-982-5490 Norwell, MA 02061-1685

**TITLE:**  
**WWTF PIPING & UTILITY PLAN**  
**CHATHAM BARS INN**  
**WWTF EXPANSION**  
**SEAVIEW STREET**  
**CHATHAM, MA**

**OWNER/APPLICANT:**  
**CBI OPERATIONS LLC**  
**297 SHORE ROAD**  
**CHATHAM, MA 02633**

DATE: SEPTEMBER 14, 2007  
 COMP./DESIGN: DMG/JCC  
 CHECK: JCC/SGC/SJS (FOR CONSTRUCTION)  
 DRAWN: LMB/DMG  
 SCALE: 1" = 10'  
 JOB NO.: ...\\dwg\Construction Plans\Design-AB  
 DWG NO.: WWTF-UT SHEET C12

**LEGEND**

	METHANOL CONDUIT
	BACKWASH
	SEWAGE PIPE
	ALKALINITY CONDUIT
	VENT
	AIR
	GRAVITY FEED
	PUMP FEED
	NEW PIPE
	PIPE TO BE REUSED (IF POSSIBLE)