

## APPENDIX B

### INFORMATION ON WASTEWATER MANAGEMENT SYSTEMS

#### B.1 OPTIONS FOR REDUCING WASTEWATER FLOWS AND LOADS

The Needs Assessment report documents the number of parcels and wastewater flows associated with five categories of wastewater management needs. As the Town identifies feasible means to address those needs, it is appropriate to ask: could the costs for satisfying these needs be reduced if the quantities of wastewater or the associated pollutant loads were reduced at the source?

#### DEFINITIONS OF "FLOWS", "LOADS" AND "CONCENTRATIONS"

It is important to understand how three terms related to one another: "flow", "concentration" and "load".

The wastewater **flow** is defined as the quantity of wastewater generated in a given time period. In this project, wastewater flows have been expressed primarily in terms of gallons per day.

The **load** of a given pollutant (say nitrogen) is the mass of that pollutant generated in a certain time period. The TMDLs for Pleasant Bay have been expressed as kilograms per day and as pounds per year, as examples.

The **concentration** of a pollutant is the ratio of its load to the flow that is transporting it. A nitrogen concentration in septic tank effluent of 35 milligrams per liter (mg/l) means 35 milligrams of nitrogen (mass) contained in one liter of septic tank effluent, for example.

These terms are inter-related. For example, untreated wastewater may have a nitrogen concentration of 45 mg/l. If the wastewater flow is 100,000 gpd, then the load is 13,700 lb/yr (See Case A below). If the flow is reduced by 10%, with no change in concentration, the load is also reduced by 10% (Case B). If the load is the same, and the flow is reduced by 10%, the concentration increases by 10% (Case C).

A.	100,000 gpd	45 mg/l	13,700 lb/yr
B.	90,000 gpd	45 mg/l	12,300 lb/yr
C.	90,000 gpd	50 mg/l	13,700 lb/yr

This interrelationship is important in understanding nitrogen control strategies. For example, reducing wastewater generation rates (by reducing water consumption) is a desirable goal, but has no effect on the nitrogen load (compare Case A with Case C). Only by reducing the mass of nitrogen in the waste stream does the nitrogen load go down.

## **BENEFITS OF FLOW AND LOAD REDUCTION**

**Collection, treatment, and disposal** are the three major structural components of a wastewater management system. The cost of a system is directly tied to the size and complexity of each component. Measures to reduce the flow or load from system users can result in reductions in system size, which can translate to a reduction in capital costs or operation and maintenance costs. Each component is affected differently by reductions in wastewater flows and loads.

### **Collection**

In traditional wastewater collection systems, there is a moderate reduction in cost associated with a reduction in wastewater flow. Within the upper reaches of the sewer system, savings are quite small, due to the fact that minimum pipe sizes are needed for maintenance purposes, and smaller volumes of wastewater do not translate to smaller pipes. Further, the cost of the pipe itself is only a very small percentage of the total construction cost. As you proceed downstream in the collection system, capital savings are more direct because pumps and pumping stations can be smaller with reduced wastewater volumes. Once the system is built, the operation and maintenance (O&M) costs piping system are largely unrelated to flow, while the energy portion of the O&M costs of pumping stations is directly related to flow.

In traditional collection systems, a reduction in pollutant load has no impact on collection system costs. However, in situations such as exist on Cape Cod, where nitrogen control governs, nitrogen load reductions can be significant. If a given embayment requires a certain nitrogen load reduction, the number of homes connected to the sewer system is directly related to the degree of nitrogen load reduction that can be accomplished at the source. A 10% reduction in nitrogen load, at the source, would translate to a 10% reduction in the number of homes to be served, resulting in a geographically less extensive sewer system and significantly reduced costs.

### **Treatment**

The capital and O&M costs of wastewater treatment systems vary with both the flow and the pollutant loads. Some plant components could be made smaller as a result of flow reductions, and others are not impacted at all. The same can be said for reductions in pollutant loads. For the technologies likely to be employed in Orleans, a reduction in nitrogen load may be slightly more advantageous than a comparable percentage reduction in flow. The best case for treatment plant cost reduction is a reduction in both flow and load.

### **Disposal**

The wastewater treatment facilities will reduce the pollutant loads to the point that they will have no impact on effluent disposal costs, either capital or O&M. Most effluent disposal technologies are sized volumetrically, that is, their size and cost is directly related to wastewater flows. Therefore, flow reduction can result in fewer or smaller effluent disposal sites.

## **On-Site Systems**

Individual systems (typically less than 10,000 gpd) are designed and constructed based on Title 5 regulations. The size of a residential system is determined based on the number of bedrooms in a residence. There are no "credits" available for implementing flow or load reduction measures, and consequently such practices do not affect the size or nature of the standard Title 5 wastewater system design requirements. (Note that Title 5 requires a larger system if the home it serves has a garbage grinder.) However, flow and load reduction can increase the longevity of an individual system. Maximizing the period between the installation of a new system and the replacement of that system at the end of its life, minimizes the annualized capital cost of the system. This is beneficial for failing systems, and can also reduce the frequency of emergency pumping. Certainly flow and load reduction at the individual level conserves water supplies and reduces nutrient loading to groundwater which reduces environmental impacts and should be considered as part of the comprehensive plan.

## **OPTIONS FOR FLOW REDUCTION**

Overall water use includes that portion that becomes wastewater and the consumptive use (the portion that does not). Reductions in consumptive use are not relevant to this discussion, but are important to town-wide water supply management. Pertinent options for wastewater flow reduction include:

### **Low-flow plumbing fixtures**

Low-flow sinks, showers, and washing machines are available and can reduce water consumption by 10% over older devices. Reducing water consumption with modern fixtures will reduce the wastewater production.

### **Outside showers**

Already common to most homes on the Cape outdoor showers are widely used in the summer time. This current practice provides a significant reduction in wastewater generation by removing this otherwise indoor activity from the wastewater stream. When many more residents are at their homes in the summer, this practice can be very beneficial. Peak wastewater flow in the summer is largely related to the surge in population. If the majority of residents take an outdoor shower after a trip to the beach, instead of an indoor shower, the opportunity exists to reduce peak flows by this practice.

### **Progressive water pricing**

Water service pricing is among the top actions to promote conservation as stated by the MA Water Conservation Standards, and an effective tool for promoting flow reduction. Contrary to the pricing structure for most services where the more you buy, the less it costs; effective water use pricing fees increase incrementally. A progressive pricing structure charges fees based on the size of the service and quantity of water used. The larger the service connection, the higher the quarterly fee. The quantity of water used is charged incrementally. Generally, the first fee

bracket covers the majority of the water used in a single family residence. Subsequent brackets are associated with higher fees. Water pricing can also change with season. It is possible to increase rates in the summer when demand is the highest. All of these practices can further the economic incentive to reduce water consumption and reduce wastewater generation.

### **Alternative toilets**

The components of domestic wastewater are often referred to as black water (that generated from flushing toilets), yellow water (separated urine, if applicable) and gray water (the composite of all remaining sources). Utilizing an alternative toilet is one method for removing black water or yellow water from the wastewater stream. Black wastewater is treated most commonly in a composting (or incinerating) toilet. Yellow wastewater would be collected in a concentrated and sent to a treatment or nutrient recovery facility. In either case, the wastewater that would have gone to the sewer is eliminated. The remaining waste that otherwise would have entered the wastewater system must be incorporated in a different waste stream. Alternatives include waste from composting toilets ending up at in a landfill or at a septage treatment facility, or incinerated waste going to a landfill. Subsequently, these locations must be able adequately handle the additional waste.

## **OPTIONS FOR LOAD REDUCTION**

### **Alternative toilets**

Alternative toilets are also an effective method of load reduction. The same technologies described above are effective means of reducing the wastewater load. The solids and nitrogen that would have gone to the sewer instead become compost (or ash) or concentrated urine, and enter a different waste stream.

### **Elimination of Garbage Grinders**

A common convenience in most kitchens is the garbage grinder. Disposing of food waste in this method can be a significant contributor to the load of the wastewater stream. Changing this practice would reduce the concentration of the wastewater stream. Many communities ban the use of garbage grinders in homes served by on-site systems. Removing food waste from the wastewater stream means that it must be incorporated into an alternative waste stream. The final destination should be weighed with the traditional practice. Many avid gardeners compost their food waste with other yard products and use the cured product as a soil amendment, and much of the nutrients are taken up by plants. Food waste can also end up in the trash. The final destination may be an incineration facility or landfill, where by-products like leachate must be treated and disposed.

## **BASIS FOR PLANNING**

By the end of the comprehensive planning process, the Town must decide on the flows and loads that will form the design basis for wastewater facilities that will be constructed. A key question will be: To what extent can the favorable flow and load reduction techniques listed above be counted on to reduce project costs?

In large part, the success of these techniques depends on public acceptability. While a town-wide ban on garbage grinders may allow a firm basis for load reduction, the benefits of all of the other techniques is difficult to quantify in advance. Therefore, the town should proceed with implementation of these options and closely monitor flows and load through the first few phases of the program, and use the results in fine-tuning later phases.

## **B.2 WASTEWATER COLLECTION SYSTEM ALTERNATIVES**

The collection system is a major structural component of a municipality's wastewater management system. The best type of collection system for a given community is determined by comparing use, capacity, costs, operation and maintenance requirements, and benefits to the specific environment and landscape.

### **OVERVIEW**

The principal components of a traditional wastewater system are:

- Collection
- Treatment
- Disposal

In some cases, there also may be significant transport facilities between the collection system and the treatment plant, and between the treatment plant and the effluent disposal site. This evaluation covers the collection system options open to Orleans, and includes all components from the source of the wastewater (typically the internal building plumbing) to the treatment plant. The pipe from the home or business to the public system in the street is called the "service connection" and it is usually the responsibility of the property owner. With some collection system options, the publicly-owned system may include components on the property to be served. This letter includes a description of conventional, low pressure (STEP and grinder pump), vacuum, and small diameter systems.

## **CONVENTIONAL COLLECTION AND PUMPING SYSTEMS**

In traditional gravity systems, wastewater flows by gravity from the house source through the service connection and through a piping network to a common collection point. At this location, a central pumping station is usually installed to lift the wastewater to another downstream stretch of gravity sewer or to transport the wastewater to its final destination for treatment and disposal. Conventional gravity systems are prevalent throughout New England. For example, the Cape

Cod towns of Falmouth, Barnstable and Chatham have gravity sewers in downtown areas and other areas of town.

Gravity sewers are normally constructed of polyvinyl chloride (PVC), ductile iron, or concrete pipe materials. Extremely flat or hilly terrain and areas with high groundwater may pose problems to gravity sewer installation. These conditions often result in increasingly deep excavations or the need for intermediate pump stations.

Wastewater pumping stations are typically located at low points in the system to collect and pump the wastewater to the next high point in the collection system or to the wastewater treatment facility. Both the deep excavations and the pump stations are expensive, and the latter represents a considerable operation and maintenance (O&M) expense.

These systems are often preferred over grinder pump or STEP systems because the municipality is in control of all the mechanical system components and has the ability to maintain the system at its own schedule. The systems are relatively simple and thus fairly reliable.

## **LOW PRESSURE SEWERS**

In a low pressure sewer system, an individual pumping system conveys the wastewater generated from the house or business into the low pressure piping network where it is transported to a central location for re-pumping or treatment. The piping network is comprised of small-diameter pipe, buried just below the frost line (typically 3 to 4 feet deep on Cape Cod), and generally following the profile of the ground. The piping system requires smaller open cuts during installation than a conventional gravity system due to the shallower depth of burial. Typical pipe diameters are 2 to 6 inches for the mains and 1.25 to 1.5 inches for the services. Each home or source uses either an effluent pump in a septic tank or a grinder pump to discharge to the main. The pressure main and service pipe are generally manufactured from PVC or high density polyethylene (HDPE).

Low pressure systems have proven to be viable alternatives especially in low-lying areas with high groundwater. Low pressure sewer systems also work well in extremely hilly areas and waterfront areas where deep excavations and extensive dewatering could cause environmental harm. Additionally, low pressure systems are well suited to installation in coastal areas subject to periodic flooding, areas with narrow streets and areas with shallow depth to bedrock.

To effectively manage a low pressure system, the Town must consider ownership of the components located on private property, the potential need for easements, limitations on system expansion, pumping system compatibility and delineation of operation and maintenance responsibilities. If the Town wishes to own the pumping system, easements will be required to permit system installation and to enable periodic and emergency maintenance to be performed. Alternately, each user could own the pumping system and schedule maintenance as needed. In this case, the Town would adopt regulations prohibiting users from modifying the system. The maintenance may be more difficult in areas of seasonal housing where residents are often not at home.

Low pressure sewers work well in some areas of the Cape and Islands because they are well suited for the relatively flat terrain, areas with perched groundwater, areas with narrow streets and properties close to surface waters. Low pressure sewers are used in Oak Bluffs, Edgartown, Tisbury, areas of Nantucket and at the Bailey's Path development in Chatham.

### **Septic Tank and Effluent Pump (STEP) Type - Low Pressure Systems**

STEP systems are a variation of the low pressure collection system that includes septic tank pretreatment. On each sewered property, there is a septic tank and septic tank effluent pump. Depending on the site layout, the septic tank can be the existing one or it may be entirely new. The septic tank of a STEP system captures the solids, grit, grease, and stringy material that could cause problems in pumping and conveyance through the small diameter piping. STEP systems can be used to convey wastewater to a treatment facility or to a common subsurface leaching system. Periodic removal of the sludge and grease collected within the septic tank by a licensed septage hauler is essential to the long term performance of the system. STEP pumps require only fractional horsepower. The City of Gloucester has 1,200 STEP systems in the North Gloucester collection system.

While standby power is easily provided to a single pump station in a treatment system, it is more difficult to keep individual grinder pumps going during an extended power outage. Some towns have used small portable generators that are moved through the neighborhood served by grinder pumps. In other cases, homeowners are on their own to provide back-up power.

### **Grinder Pump Type - Low Pressure Systems**

A grinder pump system is another variation of the low pressure collection system which utilizes a grinder pump to grind the solids present in the waste to a slurry in a similar manner as a kitchen garbage grinder. The grinder pump macerates the solids present in the raw wastewater and discharges to the low pressure piping system. Although the grinder pumps can be installed indoors, they are generally located outside, close to the user's existing septic tank or cesspool so that the service connection can be easily made with minimal alterations to the indoor plumbing. Grinder pumps which serve individual homes are usually 1 horsepower in size, but 2-horsepower units are also used. Some installations require 3- to 5-horsepower motors, and these are usually used when serving several units with one pumping unit.

### **VACUUM SYSTEMS**

Like the low pressure sewer system, a vacuum sewer system can be used where conventional sewer systems are impractical and not economically feasible. Vacuum sewers employ a central vacuum source. Vacuum sewers are limited by the available lift and are therefore most suited to flat terrain. Although not prevalent in New England, vacuum systems are in place in Provincetown, a limited area of Barnstable and on Plum Island in Newbury/Newburyport.

The collection mains in vacuum systems are typically constructed of PVC or HDPE ranging in size from 4 to 10 inches in diameter. Vacuum systems can be buried at shallow depths as the high velocities (15 to 18 feet per second) attained by the system keeps the lines from freezing. The collection mains can follow the profile of the ground provided that modest elevation changes are maintained.

The vacuum collection system consists of three main components: (1) services, (2) wastewater collection mains, and (3) the vacuum station. After a preset time interval, the vacuum valve located on each property closes and a slug of wastewater is propelled into the collection main. Numerous cycles eventually propel the wastewater to a collection tank located at a central vacuum station. Buffer tanks are also used as holding tanks to collect and regulate large flows such as those flows from apartment buildings, schools and other large users.

This technology is the newest of the options presented. It may be subject to a greater number of problems than systems that have been in use for a longer period of time.

## **SMALL DIAMETER GRAVITY SEWERS**

Small diameter gravity collection systems include a septic tank on the building service connection prior to discharge to the sewer main. The septic tank eliminates grit, grease and other troublesome solids which might cause obstructions allowing the collection system to be constructed with smaller pipe sizes. Other than pipe size, these systems are configured similar to conventional gravity systems requiring straight runs between manholes to convey wastewater to a low point where a pumping station is typically sited. Solids settlement is not as significant of a concern in a conventional gravity system, but periodic pumping of the individual septic tanks is required to remove sludge, scum and grease.

Construction costs are often reduced because the sewers may be laid to follow the topography more closely than with conventional gravity sewers. Designers must still be cognizant of infiltration and inflow and ultimate growth in sizing these systems. The Town of Westford operates a small diameter gravity system for one of its schools.

## **SUMMARY**

Table B-1 is a summary of the advantages and disadvantages of the collection system options described above.

**TABLE B-1  
SUMMARY OF ADVANTAGES AND DISADVANTAGES OF COLLECTION SYSTEM OPTIONS**

Technology	Advantage	Disadvantage
Conventional Gravity Sewer System	<ul style="list-style-type: none"> <li>• Ease of long-term maintenance</li> <li>• Power outages handled with centralized backup power at pump station</li> <li>• Provides excess capacity for future connections</li> <li>• Centralized solids management</li> <li>• Lowest energy use</li> <li>• Limited need for service connection easements</li> </ul>	<ul style="list-style-type: none"> <li>• Deep excavations disrupt traffic and private property</li> <li>• Not all properties can easily be served by gravity connections</li> <li>• Stream and road crossings more expensive</li> <li>• Not amenable to narrow streets</li> <li>• Flat areas require multiple intermediate pump stations</li> <li>• Higher capital costs</li> <li>• Interior plumbing modifications may be required</li> </ul>
Low Pressure Sewer System	<ul style="list-style-type: none"> <li>• Potential for lower capital cost</li> <li>• Easier construction due to shallow excavation</li> <li>• Environmental disruption reduced</li> <li>• Duration of construction reduced</li> <li>• Suitable for challenging terrain</li> <li>• Reduces stream and road crossing effort</li> <li>• Amenable to narrow streets</li> <li>• Less sensitivity to I/I</li> </ul>	<ul style="list-style-type: none"> <li>• Increased service call effort</li> <li>• Pumps located on each lot</li> <li>• Alarm panels mounted on buildings</li> <li>• Electrical costs paid by property owner</li> <li>• Ownership and O&amp;M responsibility are shared by many entities</li> <li>• Easements may be required</li> <li>• Must provide decentralized standby power system</li> <li>• Interior plumbing modifications may be required</li> </ul>
Vacuum Sewer System	<ul style="list-style-type: none"> <li>• Lower O&amp;M costs</li> <li>• Easier construction due to shallow excavation</li> </ul>	<ul style="list-style-type: none"> <li>• Limited number of vendors and service providers</li> <li>• Limited to flat terrain</li> <li>• Maintenance concerns with valves</li> <li>• Construction and design costs higher than low pressure systems</li> <li>• Modification to interior plumbing is required</li> </ul>

## **B.3 WASTEWATER TREATMENT SYSTEM ALTERNATIVES**

Of all the wastewater management issues identified in the Needs Assessment, protecting the health of surface waters from nutrient enrichment is the largest single concern. Wastewater effluent is the largest source of nutrients entering embayments. After addressing ways to reduce other nutrient sources such as stormwater and fertilizer, the remainder of the nutrient removal must be addressed by providing more advanced wastewater treatment. Identifying the best wastewater treatment technologies is one of the most important aspects of the CWMP.

### **INTRODUCTION**

In most cases, smaller wastewater systems cost more per user and are less reliable. To balance cost-effectiveness and reliability, This evaluation focuses on systems that are feasible at flows greater than 50,000 gallons per day. Therefore individual and cluster systems have limited applicability to this evaluation. However, this analysis will consider such systems in cases where properties with a wastewater need are in a cost-prohibitive location to reach with a sewer extension or are surrounded by other properties that adequately meet their wastewater needs.

The capital investment in a collection system is a significant portion of the overall wastewater system cost. In reducing the nitrogen load to an embayment the extent of the wastewater collection system is directly tied to the nitrogen removal capabilities of the treatment facility. Therefore, the focus will be identifying and evaluating technologies that can meet effluent concentrations less than 10 ppm.

In some cases, phosphorus control is the primary concern with respect to surface water protection. Phosphorus removal is easily achieved by chemical addition to the secondary or tertiary treatment process. Once a nitrogen removal technology is selected, an "add-on" for phosphorus removal is easily incorporated into the treatment design for those systems that serve areas tributary to ponds and lakes that require phosphorus load reduction. For this reason, this evaluation includes a detailed evaluation of nitrogen-removing technologies.

### **HIGH NITROGEN REMOVAL TECHNOLOGIES**

All the treatment systems identified herein are capable of meeting effluent nitrogen limits less than 10 ppm. The basic issues in determining which of these systems is the most appropriate include: 1) the volume of wastewater requiring treatment; 2) the relative ease of permitting the technology; 3) the projected capital and operation and maintenance expenses associated with each system; and, 4) the public acceptability of the proposed facility housing the treatment technology.

The technologies identified as part of this evaluation include: rotating biological contactors, Amphidrome, sequencing batch reactors, membrane bioreactors, biological aerated filters and oxidation ditches. A description of each technology is provided below.

There are two fundamental types of biological treatment. The bacterial mass that is the vehicle for treating the wastewater is encouraged to form either as a "suspended growth" or as a "fixed film". Activated sludge is another term for suspended growth systems in which the wastewater is mixed and aerated to provide constant contact between the bacteria and wastewater in the presence of oxygen. Sequencing batch reactors, membrane bioreactors and oxidation ditches utilize this technique. Fixed film treatment provides a surface for the bacteria to grow on that comes in contact with the wastewater. This technique is utilized by rotating biological contactors, biological aerated filters and the Amphidrome system.

### **Rotating Biological Contactors (RBC)**

Rotating biological contactors employ a series of polyethylene discs, mounted on a steel shaft. These contactors are partially submerged in the wastewater. Bacteria adhere to the discs forming a biological layer and utilize the soluble organic compounds in the wastewater as a source of energy and as a supply of the basic elements necessary to produce new cell material. Rotation of the media alternately exposes the organisms to organic-rich wastewater, and to the atmosphere which provides the oxygen needed for respiration. Second-stage RBCs are fully submerged in wastewater in covered tanks to create a low-oxygen environment where nitrogen removal occurs.

RBC's are capable of producing a fairly uniform effluent while operating over a range of hydraulic and organic loading. The biological colony will wax and wane in response to the strength and volume of the influent wastewater. This flexibility is applicable to systems that serve schools where flows significantly drop off over vacation. This technology was selected at the Dennis-Yarmouth High School for that reason. Another advantage of this fixed film process is reduced sludge production compared with suspended growth systems.

Although the majority of rotating biological contactor treatment systems in Massachusetts are constructed within a building, exterior installations using fiberglass covers have proven effective and are the norm in other areas of the country. Installing RBC's inside a building have the advantage of ready access to view and assess the condition of the equipment. Year-round temperature regulation is also possible with indoor installations. However, extra consideration is needed in selecting moisture-resistant building material that will withstand the humid environment. All installations must be above-grade.

Exterior installations may require larger RBC units to compensate for reduced bacterial treatment levels during winter months due to decreased biological activity at lower temperatures. However, the potential for lower capital costs may make this an attractive option.

RBC's have a long history of use as a biological treatment process for private and small public wastewater treatment facilities. The Community of Jesus is one local example of a small enclosed RBC treatment facility. This facility is located on privately owned land and is in a residential setting. The architectural features of the treatment facility building are suited to its surroundings. RBC's are also used at the Tri-Town Septage Treatment Facility and are located outside along with other treatment process units. The RBC's are protected by unheated fiberglass enclosures.

There are almost 100 RBC facilities with groundwater discharge permits with flows as high as 300,000 gpd in the Commonwealth. One large facility is located at New Seabury in Mashpee.

### **Sequencing Batch Reactors (SBR)**

The SBR process is a modification to traditional activated sludge treatment process, which utilizes a batch treatment system to perform the required steps of wastewater treatment. SBR systems operate on a very simple concept of introducing a quantity of waste to a reactor and providing several process steps in a sequence that would traditionally require a single tank for each step. That sequence includes filling the reactor with wastewater, providing a period of aerobic treatment, settling, and anaerobic treatment. Then the effluent can be decanted and a portion of the sludge removed before the process is repeated.

SBR's are capable of producing a uniformly high quality effluent while operating over a wide range of hydraulic and organic loadings. During periods of low hydraulic or organic loading, the biological growth can be concentrated and maintained within the reactor by reducing the frequency of sludge wasting. As the flow (or organic load) is increased, the organisms begin to proliferate and a larger percent can be removed from the system for disposal by increasing sludge wasting, while maintaining the same level of treatment. Thus, the system is quickly able to adjust to the strength and volume of the influent wastewater stream.

One of the primary attributes of the SBR system is that this variation of the activated sludge process provides considerable flexibility to meet the requirements of specific waste treatment applications. Due to process flexibility, SBRs are being employed in a variety of process design variations with increased frequency in both municipal and industrial wastewater treatment applications.

A batch treatment approach reduces the number of treatment units commonly required in traditional biological treatment facility designs. Limiting the number of process units may decrease capital costs, minimize facility footprint, and reduce treatment complexity. SBR's can be located above or below grade.

SBR's operated by municipalities on the Cape are located in Falmouth and Provincetown. Both of these installations are located in a traditional centralized treatment facility, but this technology is effective on a smaller scale as well.

### **Amphidrome**

The Amphidrome system is a fixed film sequencing batch reactor. The treatment process consists of an anoxic equalization tank, sand filters and clear well. Effluent from the anoxic tank flows downward through the sand filter, providing contact with the bacterial population adhering to the sand particles, and then flow into a clear well. From the clear well the wastewater is mixed with a supplemental carbon source and pumped through a second sand filter where the nitrogen removal process is completed. Liquid from the clear well is pumped back through the sand filter to backwash the filter and return liquid to the anoxic tank.

Amphidrome systems have been used for design flows up to 150,000 gpd. There are about 20 systems with groundwater discharge permits in the state. Amphidrome system components can be located largely below grade. The Amphidrome system at Chatham Bars Inn is a good example of a facility with minimum above-grade structures. Process tanks are located below grade in a guest parking lot, which is a good dual use of space.

### **Membrane Bioreactor (MBR)**

Membrane Biological Reactors (MBRs) includes a semi-permeable membrane barrier system either submerged in or following an activated sludge process. This technology ensures removal of virtually all suspended and some dissolved pollutants.

The membrane technology is relatively new and applicable to small and large flows. The track record of systems installed in the past few years is promising with results indicating very high effluent quality is achievable. Membranes are expensive and require regular cleaning and periodic replacement. The cost of the membrane is partially offset by the smaller building needed to house the system, compared to other technologies.

This treatment process requires a relatively small footprint. Above- and below-grade installation of the treatment process is possible. A good example of a combination of below and above grade components is the system that serves the Cotuit Stop N Shop. Several tanks are located below grade and a small treatment building houses the process tanks, pumps and controls. This facility has very high nitrogen removal.

### **Biological Aerated Filter (BAF)**

The biological aerated filter process consists of one or more units in series, depending on the level of nitrogen removal required. The BAF will require an upstream settling tank to remove the large particulate material. Each BAF unit consists of a flooded tank filled with polystyrene beads which provide the required surface area for biological growth and filter the wastewater as it passes through. The BAF unit acts as a fixed film process resulting in reduced sludge production, roughly 60%, in comparison to SBR and MBR suspended growth processes.

The BAF unit can be housed inside or outside and either above or below grade. The overall footprint of this process can be very small relative to other alternatives. This process can be intensive in terms of process controls, piping and valving requirements. Examples of this technology include the Binghamton/Johnson City Joint Wastewater Treatment Plant in New York.

### **Oxidation Ditch**

An oxidation ditch is a suspended growth system that can maintain aerobic and anaerobic treatment zones. This technology has been utilized for wastewater treatment for longer than any of the other technologies evaluated and can provide a highly "polished" effluent. Wastewater is treated as it flows around a long oval-shaped channel. Instead of providing several process tanks

like other technologies, the length of the channels allows for different types of treatment to occur as the wastewater moves around the ditch. Wastewater alternately passes through aerobic and anoxic zones allowing a mixed culture of bacteria to remove nitrogen.

This technology requires a large footprint to accommodate the ditch. Unlike other technologies the oxidation ditch is always located outside. Proper design of visual buffers and setbacks are critical in avoiding significant negative impacts on abutting properties. An oxidation ditch is used at the Yarmouth Septage Treatment Facility to treat septage. This technology has been selected for use in Chatham. Oxidation ditches are widely used in the Chesapeake Bay area.

## **SMALL-SCALE NITROGEN REMOVING SYSTEMS**

There is a wide variety of systems available to provide enhanced treatment for individual and cluster applications. In general, these systems are not capable of the highest nitrogen removal requirements. This lower efficiency is attributable to several factors, including widely ranging flows and load, less attention to operation and maintenance, and start-up time after seasonal shut-downs. In addition, these systems are relatively expensive on a per-user basis; that is, they do not enjoy the economies-of-scale that benefit larger systems. The lower efficiency and higher per-user costs translate to a higher cost per pound of nitrogen removed compared with larger systems. Where significant nitrogen control is required to protect embayments, as faced by Orleans, the focus should be on systems larger than 50,000 gpd. The applicability of small-scale systems is limited to properties, or clusters of properties, where a higher level of treatment is warranted to reduce impacts of significant Title 5 variances, and where the remoteness of the property makes the transport costs to a larger system uneconomical.

Among the most common small-scale nitrogen removing systems are: 1) Bioclere which uses a fixed-film trickling filter process; 2) Cromaglass provides treatment in a sequencing batch reactor sludge system; 3) Nitrex uses a nitrate-reactive media to convert nitrate to nitrogen gas, following a nitrification step to convert other nitrogen forms to nitrate; 4) MBRs as described above; and 5) FAST utilizes both fixed and suspended growth nitrogen removal methods.

## **SUMMARY**

Table 2-3 of the draft Alternatives Screening Report outlines the range of effluent limitations that may apply to Orleans. The five categories of effluent limits include two levels of nitrogen removal, two levels of phosphorus removal and a set of limits related to effluent reuse. This evaluation focuses on the technologies needed to meet the high level of nitrogen removal. As noted above, both levels of phosphorus removal can be achieved by adding chemical feed equipment to any of these technologies. The extra filtration provided by membrane systems yields the most reliable phosphorus removal to the lowest levels. For effluent reuse, the focus must be bacterial and viral removals and the higher suspended solids removals needed to ensure proper disinfection. Effluent reuse standards can be achieved by adding separate membrane components and efficient disinfection to any of the above-described systems, but is inherently provided by the MBR system.

The technologies identified and evaluated herein provide high levels of nitrogen removal and are most efficient when sized to treat 50,000 gpd or more. Included in Table B-2 is a summary of technologies which lists their applicability to treatment size, and the most local example of each. This table includes common small-scale systems as well.

**TABLE B-2**  
**TREATMENT TECHNOLOGIES**

Technology	Examples	Applicability to Treatment System Size		
		Less than 50,000 gpd	50,000 to 200,000 gpd	Greater than 200,000 gpd
RBC	Community of Jesus	X	X	X
Amphidrome	Chatham Bars Inn	X	X	
SBR	Provincetown	X	X	X
MBR	Cotuit Stop N Shop	X	X	X
BAF	Prominent in NY and the mid-Atlantic		X	X
Ox. Ditch	Yarmouth (septage)			X
FAST	Wrentham High School	X		
Bioclere	Wise Living	X		
Chromaglass	Carriage Crossing in East Bridgewater	X		
Nitrex	Currently Piloting at MA test center	X		

While all of the treatment technologies described in detail are capable of meeting the more stringent nitrogen limits, there are a number of subtle differences in sizing and performance that will be addressed when composite systems are evaluated for overall cost-effectiveness.

## **B.4 OPTIONS FOR EFFLUENT REUSE AND DISPOSAL**

### **INTRODUCTION**

Historically, effluent from wastewater treatment facilities has been discharged to a surface water body, be it a river, lake or ocean. In southeastern Massachusetts, the Ocean Sanctuaries Act prohibits new or expanded surface water discharges, so effluent disposal to the groundwater is the only viable option.

Groundwater effluent disposal systems fall into one of two major categories. One type applies the effluent at the ground surface, the other disperses the effluent below the surface. The goal of both is to get the effluent to percolate down to the groundwater and be carried away by the regional groundwater flow.

Surface application options include spray irrigation and rapid infiltration. Subsurface systems include leaching facilities (trenches, beds or chambers), wicks, and drip irrigation.

The relative weighting of advantages and disadvantages for a given disposal technology is best determined by considering the features of the specific site. Once potential effluent disposal sites are identified, the best pairing of sites and technologies will be addressed as composite wastewater plans are developed. The pairing depends on both the site and the disposal technology.

With respect to the physical characteristics of a site, size, topography, permeability of the soils and depth groundwater all determine suitability. Technology attributes include the opportunity for additional nitrogen removal, dual-use potential, and the effluent loading rate (volume that can be applied per square foot of area).

### **DISPOSAL TECHNOLOGIES**

From well-established technologies to those at the forefront of new designs, the technologies identified in this report were selected because they provide a wide range of capabilities, such that very different types (size, location, soils) of disposal sites can be considered.

#### **Subsurface Leaching**

By far the most common example of this type is the soil adsorption system in the typical backyard. A soil adsorption system includes of a networking of rigid perforated piping buried below grade that distributes effluent into surrounding gravel trenches or beds that provide dispersal of effluent over a large area at a low dosing rate. If well maintained they last for at least 20 years or more. Land must be available for the active disposal area as well as an equivalent area of land earmarked as reserve, which can be developed in the event of a failure.

These systems are designed to operate year-round and work best with regular dosing of effluent. The entire disposal system is buried which eliminates the chance of human contact, and can be

located under public parks or sports fields, and under parking lots with proper design. Systems can be very small like those that serve businesses in downtown Orleans, many of whom have their systems located under parking lots. The entire sewer portion of Oak Bluffs is served by a system of 28 leaching fields of 360,000 gpd capacity located under Ocean Park.

### **Drip Irrigation**

Drip irrigation is a subsurface installation of flexible small-diameter plastic piping that provides pressure dosing of effluent to the soil. Loading rates are comparable to subsurface leaching fields because the concepts are similar. This is a relatively new technology that has been tested at the Massachusetts Alternative Septic System Test Center and just received "general use" approval in 2006. These systems can be buried at very shallow depths if desired; however, shallow depths can preclude year-round operation. These systems require a pressurized application; usually a pump station is located near the disposal system and require effluent filtration to avoid plugging.

These systems can be sited under parks, sports fields, or parking lots. The flexible hosing can follow surface contours and run around trees or landscaping, and can be installed in some wooded settings. The drip tubing can be installed in the soil through narrow trenching or single blade plow. It is possible to install a system in a matter of days and avoid tearing up turf. The low-cost materials and easy installation translate into a relatively low capital cost. Due to the lack of long-term experience with the technology, DEP will probably require 100% back-up with conventional technology elsewhere. DEP may also require reuse-quality effluent when drip irrigation is used.

### **Rapid Infiltration**

Also referred to as open sand beds, these systems can operate at high loading rates on sites with good permeability and significant depth to groundwater. Year-round application is routine, but there is little opportunity for dual use of a site. The significantly reduced footprint compared with other technologies often outweighs the benefit of dual use. A smaller disposal footprint also broadens the number of parcels that could be viable disposal sites. The reduced footprint sometimes allows a single site to provide both treatment and disposal, which is less likely for other systems. Locating the treatment and disposal processes on the same site minimizes the transport costs.

The Tri-Town Septage Treatment Facility utilizes rapid infiltration basins for effluent disposal, as so does the 4-million-gallon-per-day municipal facility in Hyannis. Rapid infiltration systems require fencing around the perimeter to keep out wildlife or people. The maintenance of the system includes periodic solids removal from the application surface, and infrequent weeding.

### **Spray Irrigation**

Landscape irrigation is another example of technology that can be used on a site with another use. Effluent can be applied to parks, sports fields, golf courses, or landscaping. All of these activities are associated with human interaction and require meeting the effluent reuse

guidelines, which adds to the cost of wastewater treatment. Irrigation is certainly restricted to seasonal operation which requires either winter storage or a complementary effluent disposal system. This technique uses moderate application rates.

Yarmouth uses spray irrigation to dispose of effluent from its septage treatment facility. A portion of Yarmouth's effluent goes to a dedicated spray irrigation site with closely controlled access. The remainder of the effluent is subject to further treatment and used to irrigate the Bayberry Hills golf course.

## **Wicks**

The fundamental goal of effluent disposal is to effectively introduce effluent into the groundwater. The type of soil and the depth to groundwater affect how fast surface-applied effluent reaches the water table. Wicks are the most space-efficient method of disposal because they disperse effluent both horizontally and vertically. A wick is a vertical cylinder of highly permeable material that provides an efficient path for effluent to travel from the surface point of discharge to the groundwater. This allows for very high loading rates on a very small footprint. Another advantage to wicks is the ability to bypass less permeable material. In limited areas of Orleans, layers of clay exist that impede the ability of water to percolate through the soil. A wick provides a conduit through impervious soil at the surface to more pervious soil below.

This technology is relatively new and therefore DEP has stringent permitting requirements. First, the design must include standby wicks to provide more than 100% disposal capacity, so that if a wick were to fail or be overloaded, another wick can be brought on-line immediately. Second, there must be another permitted disposal location that could be developed with a traditional system if the wicks fail prematurely. Extensive hydrogeologic evaluations are required to determine the suitability of the soil for wicks.

While other technologies need 3 to 5 acres to distribute 100,000 gpd of effluent, the same volume could be handled by wicks on a site as small as one tenth of an acre. Wicks are not very intrusive. The only above-grade components include an access vault and cover. Wicks are best considered after an unsuccessful search for sites large enough for more traditional technologies.

Wicks are used on West Island in Buzzard's Bay and were sited on conservation land where very tight near-surface soils overlay highly permeable soil with a significant depth to groundwater. Three wicks were installed to handle 100,000 gpd. Wicks are also used for effluent disposal from a senior housing complex in Hingham. They are installed in the rough of an adjacent golf course and sized for 300,000 gpd. Both of these installations have experienced some operational problems.

## **COMBINING TECHNOLOGIES**

It is possible to combine technologies, such as year-round subsurface application below golf course fairways, and seasonal spray irrigation of the remainder on the course. It is also possible to install wicks within rapid infiltration basins to maximize the application area.

## **EFFLUENT DISPOSAL AS PART OF THE TREATMENT PROCESS**

Utilizing the disposal system as part of the treatment process is worth consideration. Specific rapid infiltration bed loading cycles can provide additional nitrogen removal. Spray irrigation of effluent removes additional nitrogen, phosphorus and most other parameters, providing effective effluent "polishing". While such polishing is well documented, DEP may not give credit for the additional pollutant removal because it is difficult to monitor and quantify.

## **YEAR-ROUND VERSUS SEASONAL APPLICATION**

Some of the technologies presented herein are limited to seasonal application. Providing storage of wastewater in cold weather would be required if spray irrigation were the only selected technology. Instead, some combination of technologies is a viable option. Pairing, say year-round rapid infiltration with seasonal spray irrigation could match the typical Cape Cod fluctuation in population and associated flow, and thus avoid winter storage.

## **REUSE: DEFINITIONS AND BACKGROUND**

DEP uses the term "reclaimed water", which it defines as "wastewater that has been treated at a wastewater treatment plant to an advanced degree and used again for various purposes."

The fundamental premise behind any reuse program is recognition of the value of water and the nutrients it may carry, tempered by the public health aspects of public contact with wastewater-derived material. The allowable effluent disposal methods following traditional wastewater treatment (rapid infiltration, subsurface disposal, etc.) are in large part aimed at getting the effluent into the ground, and keeping it there, thus protecting the public from contact with a liquid that retains some undesirable characteristics even after tertiary treatment. The DEP reuse program stipulates higher levels of treatment that address those undesirable characteristics so that certain levels of human exposure are tolerable.

A good way to contrast "effluent disposal" and "use of reclaimed water" is to consider spray irrigation. A spray irrigation site that receives typical treatment plant effluent must include fencing or other means of preventing public access, as well as significant vegetated buffers to control spray drift. If a higher level of treatment is provided, the DEP program allows spray irrigation on golf courses where the public has access. The first example of spray irrigation is best termed "effluent disposal"; the second is "use of reclaimed water".

## **NATIONAL REUSE EXPERIENCE**

In many water-short regions of the country, effluent reuse has been widely employed to counter low stream flow conditions, dropping water tables, and inadequate potable water supplies that are taxed by non-potable uses, such as irrigation. There are hundreds of examples of effluent reuse in states such as California, Texas and Florida. One of the most extensive examples of effluent reuse is in St. Petersburg Florida, where reclaimed water is pumped through an irrigation

water supply system to residential neighborhoods where it is used, with some restrictions, for private lawn watering.

## **REUSE EXPERIENCE IN MASSACHUSETTS**

Reclaimed water is used for toilet flushing at Gillette Stadium in Foxborough, at a car wash in Westford, for golf course irrigation in Yarmouth, for cooling water at a power plant, and for toilet flushing at the Wrentham outlet mall.

## **MASSACHUSETTS REGULATORY PROGRAM**

Massachusetts DEP has established a program to guide the reuse of wastewater effluents. Its publication "Interim Guidelines on Reclaimed Water" was issued in January 2000, and is about to be updated. Alan Slater leads the DEP program, and he met with the Wastewater Management Steering Committee on September 20, 2007 to discuss the current and upcoming guidelines.

The current guidelines allow four types of reuse:

- Spray irrigation of golf courses
- Reuse at landscape nurseries
- Artificial aquifer recharge, and
- Toilet flushing

More uses may be allowed under the new guidelines, perhaps including include private lawn irrigation.

For artificial aquifer recharge, DEP divides projects into two categories:

- The effluent is discharged at a point where the groundwater travel time to the nearest water supply well is more than 2 years, or
- The groundwater travel time is less than 2 years.

## **LEVEL OF WASTEWATER TREATMENT PRIOR TO REUSE**

Wastewater reuse requires a higher quality effluent compared to traditional effluent disposal, and it is important to understand the effluent limits that DEP will apply to the plant producing the reclaimed water. Table 2-3 in Section 3 of this report summarizes the likely effluent limits for a range of scenarios including reuse. Consider the key regulated parameters of BOD, suspended solids, nitrogen and fecal coliform:

- **BOD**, or Biochemical Oxygen Demand, is a broad measure of organic material in the wastewater that consumes oxygen as it decays. The traditional limit on BOD is 30 mg/l. For golf courses and nurseries, and for aquifer recharge with less than 2-year travel time, the BOD must be reduced to 10 mg/l.

- **TSS**, or total suspended solids, is a measure of the solid material that would remain if the effluent were passed through a fine laboratory filter. The traditional limit on TSS is 30 mg/l. For reuse applications, the TSS must be reduced to either 5 mg/l (landscape irrigation and less-than-2-year-travel-time aquifer recharge) or 10 mg/l (toilet flushing or more-than-2-year-travel-time aquifer recharge). The primary reason to reduce TSS is to improve the effectiveness of downstream disinfection processes. The most common disinfection process, exposure of the effluent to intense ultraviolet light, is very sensitive to the TSS level. Turbidity is another measure of suspended matter, that is easily detected with an in-line device that can continuously measure and record the degree to which light is prevented from passing through the effluent by suspended material. DEP requires that turbidity be continuously below 5 turbidity units (NTUs) for all reuse applications, and that the average of all readings be below 2 NTU for landscape irrigation and aquifer recharge with less than 2-year travel time.
- **Nitrogen** comes in many forms, the principal of which are organic nitrogen, ammonia and nitrate. The typical discharge permit limits the sum of these nitrogen forms to 10 mg/l and also limits the nitrate form to 10 mg/l (which is also the drinking water limit). For effluent reuse, no further nitrogen removal is needed; indeed for landscape irrigation, the presence of nitrogen is a good thing.
- **Pathogenic material** is present in wastewater, and includes such things as bacteria, parasites and viruses that are difficult to measure individually. Fecal coliform bacteria are used as an indicator of the likely presence of pathogens, and are measured as the number of colonies that will grow in a Petri dish under controlled conditions from 100 milliliters (ml) of sample. Although groundwater discharge permits have historically not explicitly required disinfection, DEP is increasingly imposing a limit of 200 fecal coliform colonies per 100 ml, as an **average**, on new discharges. In the reuse setting, that 200 col/100ml standard applies to more-than-2-year-travel-time aquifer recharge, as the **maximum** for any one sample. The maximum fecal coliform count is only 100 col/100ml for toilet flushing and only 14 col/100ml for landscape irrigation and less-than-2-yr-travel-time aquifer recharge. For aquifer recharge and for landscape irrigation, DEP also requires that the **median** fecal coliform count be "zero". That is, more than half of the effluent fecal coliform counts in a given week must be zero.

## AVAILABLE TREATMENT TECHNOLOGY

Given the effluent limits discussed above, wastewater treatment systems that produce effluent suitable for reuse must provide a higher-than-normal removal of BOD and TSS, normal levels of nitrogen, and very-high-quality disinfection. Many of the local reuse applications have employed membrane bioreactors (MBRs), such as the WMSC visited in 2006 at the Cotuit Stop n Shop. Another applicable technology uses chemical precipitation to enhance TSS removal. In both cases, a high-intensity ultraviolet disinfection system would be included, although disinfection with ozone is also a possibility.

High quality effluent is required for reuse, and that high quality must be consistently achieved. Treatment plants must be designed for a higher-than-usual level of reliability, and extra monitoring is needed.

The demand for reclaimed water may vary seasonally and would be impacted by the weather. Therefore, DEP requires that a conventional effluent disposal system be provided as a back-up for all effluent reuse programs that involve landscape irrigation (golf courses and landscape nurseries).

## **ASSURANCES AND OPERATIONAL CONSIDERATIONS**

A enforceable contract is necessary between the supplier of reclaimed water and the user, and its principal terms are stipulated by DEP. The user must agree to implement Best Management Practices (BMPs) to avoid or mitigate undesirable impacts. Through the groundwater discharge permit, the supplier of reclaimed water, in this case the Town, is ultimately responsible for the user's failure to use BMPs.

Signs must be posted at key locations where reclaimed water is used, to alert the public to its non-potable character. Use of reclaimed water must be limited to hours when the public is not present at golf courses and nurseries. Reclaimed water cannot be used inside greenhouses.

## **POSSIBLE REUSE APPLICATIONS IN ORLEANS**

Reclaimed water could be produced for a single large user, connected to the treatment plant by a dedicated pipeline. Alternatively, a high quality effluent would be produced at, say, the Tri-Town site, and a reclaimed water distribution system could be installed to serve a number of possible customers in the westerly portion of town. Those customers would be allowed to tap into the distribution system and their connection piping would include a meter that would allow the Town to document the volume used and, if appropriate, issue a bill for that water.

The following list of potential customers and uses was discussed with Alan Slater of DEP at the WMSC meeting on September 20, 2007:

1. **Toilet Flushing in Public Buildings.** Reclaimed water could be used to flush toilets at the Town Hall, the fire station, the police station, the highway garage, the public toilets on Main Street, the Snow Library, and similar facilities. Administrative issues would be reduced (compared to private reuse) because of Town ownership. Internal plumbing changes would be needed. Presumably, all of these buildings would be connected to the public sewer, so the reused water would return to the treatment plant.
2. **Lawn Irrigation at Public Sites.** The Town could use reclaimed water to irrigate lawns and vegetation at all of the sites listed above. To the extent that irrigation systems have already been installed, they could merely be disconnected from the potable water supply (or from on-site irrigation wells) and re-connected to the reclaimed water distribution system. The reused water would infiltrate to the groundwater. Best Management Practices would govern the application rates (to avoid runoff, for example) and other

operational issues, but presumably groundwater discharge permits would not be required at each individual site.

3. **Toilet Flushing at High-Water-Consumption Commercial Establishments.** Compared with Item 1 above, providing reclaimed water to restaurants and motels increases the administrative burden, but it significantly increases the volume of reused water. Most of the high water users would be connected to the public sewer, so the reused water would be returned to the treatment plant.
4. **Irrigation of the Natural Areas within the Route 6/Route 6A Interchange.** Above-ground irrigation piping could be used to apply reclaimed water in these wooded areas. No vegetation removal would occur. An agreement would be struck between the Town and Mass Highway to control the application operation.
5. **Irrigation of NStar Rights-of-Way.** The Town should expect that NStar will not be in favor of permanent wastewater disposal facilities under and near its power lines. Irrigation through above-ground, removable distribution equipment might be a more acceptable alternative. Control of vandalism would be an issue, unless sites were fenced off, something that NStar might support. With irrigation of NStar rights-of-way, it would be important to address the pruning of excessive vegetation, a regular concern of NStar.
6. **Irrigation of Cemeteries.** Town Counsel has expressed concern about effluent disposal at cemeteries because of the likely difficulty in gaining all necessary approvals and sign-offs from individual plot owners. These concerns might be addressed by the Town selling irrigation water (effluent meeting the Reclaimed Water Guidelines) to the cemetery association or other controlling entity. Presumably, the extra treatment and monitoring provided to produce reclaimed water would change the character of the liquid from "a waste material requiring disposal" to "valuable alternative irrigation water", and eliminate some of the legal concerns.
7. **Irrigation of Golf Courses with Reclaimed Water.** This option is already addressed in the current DEP guidelines. Given the fact that there are no golf courses in Orleans, this option would require approval and close cooperation with Brewster where several golf courses are located.
8. **Irrigation of Golf Courses with Effluent-Impacted Groundwater.** At the Pinehills in Plymouth, golf course irrigation wells intercept a significant portion of the plume from the development's effluent disposal system, thus recycling some of the wastewater nitrogen entering the groundwater. If Orleans and Brewster developed a rapid infiltration site upgradient of one of the Brewster golf courses, and used capture wells to produce irrigation water, the Reclaimed Water Guidelines might not apply, avoiding the higher level of treatment.
9. **Irrigation of Ball Fields.** The Elementary and Middle School playing fields have been identified as potential sites of subsurface leaching facilities for effluent disposal. Instead, reclaimed water might be used to irrigate those fields, eliminating the demand on the potable water system (or local irrigation wells) and providing additional nutrient uptake.

The new Reclaimed Water Guidelines are expected to address this option. The Town should consider a dual system, involving both warm-weather irrigation of reclaimed water and cold-weather subsurface disposal of effluent.

10. **Irrigation of the Bike Path.** A permanent irrigation system could be installed along the Bike Path, enabling seasonal irrigation of the vegetation along the old railroad right-of-way. Presumably this option would be akin to irrigation of playing fields, since it presents some of the same risks such as exposure of children.
11. **Irrigation of Land Surrounding the Radio Tower.** This open land near the Tri-Town plant was initially identified as a potential effluent disposal site, before realizing it has relatively shallow groundwater. If the Town were to build a subsurface leaching system there, surrounding the tower, could it apply reclaimed water there to offset the lack of the usual 4 feet of groundwater separation?
12. **Irrigation of Capped Landfill.** The closed landfill could be considered as a site for a dedicated spray irrigation facility, where the application rates would be controlled to limit runoff, and a hay crop could be grown to remove nitrogen and phosphorus. The landfill is near the potential route of a reclaimed water distribution system. DEP might require the use of reclaimed water instead of the traditional 30/30/10 effluent.
13. **Irrigation of Private Lawns.** If the proposed distribution system passes through residential neighborhoods, reclaimed water could be sold to individual homeowners. There would be more administrative costs here than with a single public or quasi-public landowner, but much more potential for widespread use and public acceptance. This reuse option could be associated with a "reuse loop" from a centralized facility at Tri-Town, but it could also allow reuse near any decentralized plant that might be built, provided the appropriate level of treatment is assured.
14. **Irrigation at Private Nurseries.** Private landscape nurseries could be provided with reclaimed water from the distribution system. This use is covered in the existing Reclaimed Water Guidelines.
15. **Irrigation of Private Tree Farms.** There is at least one private tree farm in the region (off Route 39 in Brewster). The use of reclaimed water here would presumably be similar to the private nursery situation.
16. **Use at Car Washes.** There are two car washes that could easily be served by the proposed reclaimed water distribution system; one at the Underground Mall (open to the public) and one at the Toyota dealership near the landfill. DEP has previously approved reuse at a commercial car wash on an experimental basis, so there is some precedent for this application.
17. **Irrigation of Wellfields Outside of Zone 2.** Some of the Town wellfield property is located outside the mapped Zone 2 boundaries. If convenient to the proposed distribution system, might such land be irrigated with reclaimed water? If not prohibited by the Town Meeting language through which the land was acquired, this reuse opportunity would not be covered by the current DEP guidelines.

- 18. Use in Concrete Production.** Cape Cod Ready Mix in Brewster near the Orleans line uses water for a number of purposes in its business. Might reclaimed water be an appropriate substitute?

This list of potential reuse opportunities was developed to provoke some innovative thinking and to elicit input from DEP on regulatory issues. DEP was generally supportive of these concepts and offered to work with the WMSC to develop a specific plan.

## **B.5 NON-TRADITIONAL NITROGEN CONTROL OPTIONS**

In the needs assessment phase of the CWMP, it was demonstrated that the control of nitrogen is the largest driving force toward improved wastewater management in Orleans. Nitrogen reaches the embayments from various sources and through multiple pathways. The "traditional" approach to controlling nitrogen is to replace septic systems with public wastewater facilities that remove large amounts of nitrogen, and discharge the effluent either at appropriate locations within the watershed, or in the watershed of a less sensitive embayment. While public sewerage is a readily permitted and predictable method for nitrogen control, it is also very expensive. There are a number of "non-traditional" methods for nitrogen control that offer significant cost savings.

### **INTRODUCTION**

In broad terms, non-traditional controls fall into the following categories:

- Options that prevent future nitrogen loads;
- Options that reduce current nitrogen loads before they reach the groundwater;
- Options that take advantage of natural processes that impact groundwater quality as it moves toward the embayments;
- Options that improve the ability of the embayments to assimilate nitrogen loads; and
- Options that remove nitrogen from the water column or sediments within the embayments.

Within that context, the following nitrogen control methods were considered:

- Density controls through municipal bylaws or regulations
- Control of fertilization
- Stormwater management
- Natural attenuation
- Permeable treatment barriers
- Flushing enhancements

- Aquaculture
- Removal or modification of sediments

## **DESCRIPTION OF OPTIONS**

### **Density Controls through Municipal Bylaws and Regulations**

The Needs Assessment documents how current wastewater generation rates in Orleans are expected to increase by 22% over the planning period ending in 2030. Considering a somewhat lower rate of increase in non-wastewater nitrogen sources (such as lawn fertilization), the town-wide nitrogen load may increase by about 20% as a result of growth in the community. Town-wide, the **current** nitrogen load must be reduced by perhaps 20% to 25% (depending on the findings of the MEP studies for the Nauset system). The **growth** in nitrogen load is approximately the same as the amount of the **current** load that must be removed. Any steps the Town can take to slow the growth in nitrogen load will directly impact the extent and cost of structural solutions.

Possible land use controls were discussed in detail at a September 21, 2006 joint meeting of the Board of Health, the Planning Board and the WMSC. The most promising options include:

- Reducing minimum lot sizes for new residential development or reducing the allowable development intensity on commercial properties;
- Instituting nitrogen-based performance standards for expansions and redevelopment, such as the "no net nitrogen increase" approach or a maximum pound-per-acre load (the "fair share" approach);
- Accelerating land purchases or conservation easements; and
- Instituting a "checkerboard" sewer system with limitations on increased flows from properties not served.

These and other programs will be further developed as part of the non-structural plan that will be part of the final CWMP.

### **Control of Fertilization**

When lawn and garden fertilizer is applied, some portion of the nitrogen nourishes the plants, another portion is converted to harmless nitrogen gas by soil organisms, and the excess nitrogen leaches to the groundwater. The MEP technical report for Pleasant Bay estimated that 30% of the un-attenuated nitrogen load from the watershed comes from fertilizer and stormwater runoff, with most of that from fertilizer. Therefore, after septic nitrogen, fertilizer nitrogen is the next largest source. In the Pleasant Bay sub-watershed (one portion of the overall watershed), nearly one-half of the watershed nitrogen load comes from lawn fertilization, principally from three golf courses within that watershed.

There are many steps that can be taken to reduce fertilizer nitrogen load to the groundwater. First, fertilized lawn area can be reduced. Second, where fertilizer is used, the application rate can be reduced, and the timing of applications can be spread out. Third, fertilizers with organic slow-release nitrogen can be substituted for traditional inorganic forms. These steps can be taken by all fertilizer users, but the greatest potential for reduction is where large fertilizer use occurs, which includes golf courses, town parks, and school district ballfields.

The MEP technical report for Pleasant Bay assumed that the typical lawn in Orleans leaches 1.08 pounds of nitrogen per year. That report also refers to a separate SMAST study of lawn care in Orleans which found significantly higher fertilizer use (and presumably nitrogen leaching) on those homes that use private lawn services. One might conclude that private lawn care should be curtailed, but an alternate approach might be to work with the private lawn care companies to seek modified application procedures and materials that might allow green lawns at substantially lower risk of nitrogen leaching.

Education of the public on the need to modify lawn care practices should occur regardless of other steps. In addition, the Town should institute changes in its own practices and should work with the school district in a similar fashion. Other possible steps include restriction on lawn area in new development, working with local lawn and garden retailers to stock only more appropriate fertilizer products, and working with the County to institute a fertilizer ban. While not within the direct control of Orleans, every effort should be made to reduce the very large fertilizer use in the Pleasant Bay sub-watershed at golf courses in Brewster, Harwich and Chatham. Controls on fertilizer use on cranberry bogs should also be considered as appropriate.

### **Stormwater Management**

Precipitation that falls on impervious surfaces runs off and takes with it a variety of pollutants, including nitrogen. If stormwater is discharged directly to a pond or embayment (or to a pipe or channel leading directly there) it is considered a "point source". If runoff infiltrates into the ground and transports pollutants to the groundwater it is considered a "nonpoint source". In either case, actions are warranted to reduce the pollutant load from stormwater. For all of Pleasant Bay, runoff from impervious surfaces is estimated to produce 9,000 pounds of nitrogen per year, or 9% of the total un-attenuated load from all watershed sources.

In general, the Town should try to remove all point sources by infiltrating stormwater instead of discharging it to surface waters. Where this is not possible, some "end-of-pipe" treatment may be warranted, such as exists at Lonnie's Pond. While infiltration is most efficient through bare soil, vegetated surfaces provide considerable pollutant removal. Pollutants in runoff can also be addressed at the source, through such programs as regular street sweeping, owner control of pet wastes, requirements for nutrient management plans for large developments, etc. In some communities, surface waters have been significantly impacted by runoff from failed septic systems. The investigation of sewer needs in Orleans have found this problem to be non-existent.

There are many reasons why stormwater management should occur in Orleans independent of nitrogen control. Phosphorus transport to ponds is an important issue, as is bacterial

contamination at beaches and shellfishing areas from road runoff. These reasons for stormwater management are important enough on their own to warrant a town-wide plan. Implementation of that plan will also reduce nitrogen loads to embayments.

### **Natural Attenuation**

As groundwater moves toward and into embayments, it may pass through freshwater ponds and bogs and through salt marshes. In these environments, there may be some removal of nitrogen by natural means that lessens the impact on the embayment. These processes are called "natural attenuation". Natural attenuation has been included in the modeling of embayments on Cape Cod as part of the Massachusetts Estuaries Program. For Pleasant Bay as a whole, natural attenuation is estimated to reduce the raw watershed nitrogen load by 4%.

Natural attenuation can be part of Orleans' overall plan in several ways. First, the selection of properties to be connected to traditional wastewater systems should focus on those properties that are not subject to natural attenuation; that is, once pond protection needs are addressed by sewerage in areas immediately upgradient of ponds, wastewater collection should focus first on those properties that are downgradient from the ponds and wetlands that provide natural attenuation.

Second, effluent disposal sites can be located upgradient from these natural attenuation resources to allow further pollutant removals as the effluent-impacted groundwater moves toward the embayment. Great care must be taken to avoid secondary impacts, however, such as overloading the nitrogen attenuation capacity or introducing more phosphorus than is appropriate. Some studies have shown that salt marshes may have significant nitrogen removal capability with less potential for overloading than freshwater systems. In Orleans, where pond protection has high priority, salt marshes represent the best opportunity for natural attenuation and should be considered in effluent disposal siting. The Tri-Town site in Orleans is upgradient from Namskaket Marsh, and the marsh that may now be providing renovation of the Tri-Town plume and might provide attenuation of nitrogen from wastewater effluent infiltrated at the Tri-Town site. Similarly, the salt marshes separating Pochet Neck from Pochet Creek might provide a similar benefit for effluent disposed of in areas that are immediately upgradient.

The third opportunity for taking advantage of natural attenuation is in the restoration of damaged wetlands or the conversion of abandoned cranberry bogs. Some natural attenuation may be occurring at these locations, and restoring them to their original state may allow additional attenuation. In cranberry bogs, deepening the bog or increasing the water surface may increase the detention time of groundwater passing through these systems and allow for greater natural attenuation.

### **Permeable Treatment Barriers**

Permeable treatment barriers are narrow, deep trenches excavated along the shoreline and filled with a medium such as wood chips. The wood chips provide the substrate for bacteria that remove nitrogen from the groundwater passing through the trench. This option, in concept, partially replicates some of the features of riparian wetlands that provide natural attenuation.

This method of nitrogen control is very focused in that it intercepts whatever nitrogen has previously reached the groundwater in the watershed upgradient of the barrier. In order for the barrier to remove significant percentages of the nitrogen reaching the embayment, it must cover a large portion of the shoreline and must be deep enough to intercept most of the vertical depth of the nitrogen-impacted groundwater. This approach has been pilot tested at locations in Rhode Island and on Cape Cod. Drawbacks include the need to obtain property rights along the shore, the potential for construction impacts, and the uncertain frequency of media replacement.

### **Flushing Enhancement**

The residence time of nitrogen in an embayment in part determines the susceptibility of that embayment to water quality degradation. Enhancing the flushing rate of the embayment can improve water quality and lessen the impacts of a given nitrogen load. Dredging channels, widening inlets and replacing constricting culverts are all ways to enhance tidal flushing. A number of sub-embayments in the Pleasant Bay system (for example Lonnie's Pond and Areys Pond) and perhaps the Nauset system could potentially benefit from dredging to deepen their inlets. It is expected that less nitrogen control would be needed in the watersheds of these sub-embayments after dredging of their inlets, although additional modeling of the hydrodynamics and water quality would be needed to quantify the impact. (It is important to note that enhanced flushing in these "headwaters" sub-embayments does not reduce the overall load to the Pleasant Bay system, but merely moves the load downstream more quickly. In that these sub-embayments are influenced by the quality of the downstream waters that flush them, this technique is less attractive than similar actions in embayments that discharge directly to the Atlantic Ocean or Cape Cod Bay.)

The MEP technical report for Pleasant Bay predicts that a significantly higher level of nitrogen control will be needed if the current breach off Chatham reverts to its prior, more southerly location. The principal behind this conclusion is the same as discussed above. The towns around Pleasant Bay should formulate a plan to deal with this possible "flushing diminishment".

Flushing enhancement options have many advantages and disadvantages. Any modifications to the coastal environment require significant permitting. Dredging is only permissible in the ACECs if that location has been previously dredged. (Historical dredging has occurred in Areys Pond, Lonnie's Pond and Paw Wah Pond, and perhaps others.) The nitrogen control needs documented in the MEP technical report are intended to restore eelgrass and habitat for benthic organisms. Dredging would certainly destroy, at least temporarily, some of the habitat that the nitrogen control is intended to benefit. Dredging, if permissible, would not be a one-time event, but would need to be repeated over time to maintain the flushing enhancement.

### **Aquaculture**

Shellfish are filter-feeders; they filter water to capture organic matter, and in so doing take up nitrogen. By harvesting the shellfish, the nitrogen is removed from the water column. Some studies have been conducted on Cape Cod to assess the viability of aquaculture systems as part of a planned nitrogen removal program. This nitrogen control option is attractive because it might actually generate revenue in excess of its costs. However, it has not been studied

sufficiently for it to be included in a formal program. Nonetheless, it is sufficiently attractive to warrant the close review of any ongoing studies to document its effectiveness and economics.

### **Sediment Removal or Modification**

The release of nitrogen from sediments in the embayments represents a large percentage of the total nitrogen load. MEP studies have categorized this nitrogen source as not "controllable" due to the difficulties in removing the sediments or effecting changes in their geochemistry to reduce nitrogen release. While the details of this option and its feasibility need to be better determined, the Town should support investigations and stay abreast of progress on this front. To put this issue in perspective, the nitrogen removal predicted by the MEP technical report for Pleasant Bay is about 37,000 lb/yr, while the current benthic demand is 187,000 lb/yr.

### **APPLICABILITY OF OPTIONS TO ORLEANS' CWMP**

As one reviews the options described above, it is important to keep in mind several factors.

- First, these options hold considerable promise as low-cost substitutes or supplements to traditional systems.
- Second, there are significant permitting and approval hurdles for some options that may make them impractical over the near term.
- Third, there is the need to develop a mechanism to demonstrate the effectiveness of any of the options that is implemented. That is, it is not sufficient to merely **estimate** the degree of nitrogen removal that may occur. It is also necessary to **document** the extent to which nitrogen loads are being reduced. While this is easily done with the discharge from a wastewater treatment plant (by monitoring the effluent), how would it occur with a fertilizer control program, or the restoration of an abandoned cranberry bog?
- Fourth, DEP must concur with the nitrogen control capabilities of any of these options. When the CWMP is approved, DEP must concur in the capabilities of each aspect of a multi-pronged approach. If DEP is not convinced that one of these non-traditional options will be effective, the Town might have to modify the CWMP to include more extensive traditional controls.

None of these issues constitutes a "fatal flaw", but they are very important considerations as these options receive further review and are incorporated into composite plans later in this phase of the project.